

ROUTINE WATER CONTROL LOG

Model based on Annex IV · Decreto 99/2024 (Madrid region)

FACILITY: POOL: Disinfectant: Week of:

DATE	TIME	pH	Disinfect. (mg/L)	Turbidity (NTU)	Transp.	Recirc. time (h)	Water T (°C)	Air T (°C)	RH (%)	CO2 in/out (ppm)	Other	PERSON	Remarks
	opening												
	mid												
	opening												
	mid												
	opening												
	mid												
	opening												
	mid												
	opening												
	mid												
	opening												
	mid												
	opening												
	mid												
	opening												
	mid												

Legal values (RD 742/2013, Annex I): pH 7.2–8.0 · Free chlorine 0.5–2.0 mg/L · Total bromine 2–5 mg/L · Turbidity <= 5 NTU · Bottom drain visible · Water T 24–30 °C (heated pools)

Test at least twice a day: in the morning before opening and halfway through opening hours (art. 16.2.b). Air temperature, humidity and CO2: indoor pools only.
Orientative template prepared by Piscinas D'Martinez from the Annex IV model of Decreto 99/2024 (BOCM 31-10-2024). Keep it at the pool, available to inspectors (art. 33).